



**Planning,  
Industry &  
Environment**

Place Management NSW Level 6, 66 Harrington Street,  
The Rocks, NSW 2000  
PO box N408, Grosvenor Place 1220  
02 9240 8500

SHEET #:  
**60**

SITE: **VH - BlankMap - Tallawoladah Lawn**

EVENT NAME:

SITE CONTACT: **Place Management NSW**

CONTACT NUMBER:

DATE: **6 -7 August, 2022**

DRAFTSPERSON:  
**Victor Lam**

SCALE:  
**(as bar scale)**

PAPER SIZE:  
**A3**

ISSUE DATE:

LEGEND:

**DISCLAIMER**  
This plan is a guide of the site and may not reflect actual dimensions or infrastructure. Please inspect the site to ensure it meets your requirements.

**WEIGHT LOADING**  
Please advise your PMNSW representative of any infrastructure or transport that exceeds 10 ton, prior to bringing on site.

ID	Basic Electrical Information	Location	Detail Info.
70	50amp 240V		MCA Lawn - North Pitt 2 x 3phase 50am. 2 x single phase 10amp
71	20amp 240V		MCA Middle Pitt, 1 x 3phase 50amp. 1 x 3phase 40amp. 1 x 3 phase 32 amp. 1 x single phase round pin 20amp, Middle Pitt
79	40amp 415V		MCA Lawn - Middle Pitt 1 x 3phase 50amp. 1 x 3phase 40amp. 1 x 3 phase 32 amp. 1 x single phase round pin 20amp
96	32amp 415V		Middle Pitt MCA Lawn, 1 x 3phase 50amp. 1 x 3 phase 32amp. 1 x single phase round pin 20amp.
97	20amp 5pin switched outlet 415V		MCA Middle Pitt, 1 x 3phase 50amp. 1 x 3phase 40amp. 1 x 3 phase 32 amp. 1 x single phase round pin 20amp.
75	50amp 415V		MAC Lawn - MCA Middle Pitt 1 x 3phase 50amp. 1 x 3phase 40amp. 1 x 3 phase 32 amp. 1 x single phase round pin 20amp.
73	50amp 415V		MCA Lawn - North Pitt , 2 x 3phase 50am. 2 x single phase 10amp
74	50amp 415V		MCA Lawn - North Pitt, 2 x 3phase 50am. 2 x single phase 10amp.
78	40amp 415V		MCA Lawn - South Pitt , 1 x 3phase 50amp. 1 x 3phase 40amp
57	10amp 3pin RCD protected double GPO 240V	Single phase, Playfair Street above Caminetto garbage room door	Single phase
6	20amp 3pin GPO 240V	Cleland bond main witch room	Single phase
17	15amp 3pin switched outlet 240V	Cleland bond main witch room	Single phase

